

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240093

Product: Electrical cables with thermoplastic PVC insulation and sheath; fixed wiring

Type: CYKY, CYKYLo

Rating: CYKY - (2-5) x (1,5-6) mm², (4-5) x (10-16) mm², (7-18) x (1,5 and 2,5) mm², 7 x 4 mm²; 450/750 V
CYKYLo - (2-3) x (1,5-4) mm²; 450/750 V

Ordering firm: Tele-Fonika Kable S.A
Hipolita Cegielskiego 1, 32-400 Myślenice, Poland

Manufacturer: Tele-Fonika Kable S.A
Hipolita Cegielskiego 1, 32-400 Myślenice, Poland

Factories: Tele-Fonika Kable S.A
Hipolita Cegielskiego 1, 32-400 Myślenice, Poland

Trade mark:

The test results are stated in the test-report No.: 240261-01/01 of: 28.02.2024

A sample of the product was found to be in conformity with:

ČSN 34 7411:2014, ČSN EN 50363-3:2006+A1:2012, ČSN EN 50363-4-1:2006, ČSN EN 50395:2006+A1:2012,
ČSN EN 50396:2006+A1:2012, ČSN EN 60811-100:2013, ČSN EN 60811-201:2013+A1:2018,
ČSN EN 60811-202:2013+A1:2018, ČSN EN 60811-203:2013, ČSN EN 60811-401:2013+A1:2018, ČSN EN 60811-409:2013,
ČSN EN 60811-501:2013+A1:2019, ČSN EN 60811-504:2013, ČSN EN 60811-508:2013+A1:2018,
ČSN EN 60811-509:2013+A1:2018, ČSN EN 60332-1-1:2005+A1:2016, ČSN EN 60332-1-2:2005+A1:2016+A11:2017+A12:2024

Other data:

The validity of the certificate is limited to: 04.03.2027

05.03.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body

Stamp



240261-01