

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ÉLECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1180144

Product: Electronic cables with thermoplastic PVC insulation and sheath; fixed wiring

Type: CYKY, CYKYL0

Rating: CYKY - (2-5) x (1,5-6) mm², (4-5) x (10-16) mm², (7-18) x (1,5 a 2,5) mm², 7 x 4 mm²; 450/750 V
CYKYL0 - (2-3) x (1,5-4) mm²; 450/750 V

Ordering firm: Tele-Fonika Kable S.A.
Hipolita Cegielskiego 1, 32-400 Myslenice, Poland

Manufacturer: Tele-Fonika Kable S.A.
Hipolita Cegielskiego 1, 32-400 Myslenice, Poland

Factories: Tele-Fonika Kable S.A.
Hipolita Cegielskiego 1, 32-400 Myslenice, Poland

Trade mark:

The test results are stated in the test-report No.: 800396-01/01 of: 27.02.2018

A sample of the product was found to be in conformity with:

ČSN 34 7411:14, ČSN EN 60811-100:13,
ČSN EN 60811-201:13, ČSN EN 60811-202:13, ČSN EN 60811-203:13,
ČSN EN 60811-501:13, ČSN EN 60811-401:13, ČSN EN 60811-504:13,
ČSN EN 60811-505:13, ČSN EN 60811-508:13, ČSN EN 60811-509:13,
ČSN EN 60811-409, ČSN EN 50395-06+A1:12, ČSN EN 50396-06+A1:12,
ČSN EN 50363-3-06+A1:12, ČSN EN 50363-4-1:06, ČSN EN 60332-1-1:05+A1:16,
ČSN EN 60332-1-2:05+A1:16+A11:17

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ" certificate" certification scheme and on the basis of agreement No. 800396 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.03.2021

07.03.2018

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



800396-01